



RESEARCH-DEVELOPMENT AND TESTING NATIONAL
INSTITUTE FOR ELECTRICAL ENGINEERING

ICMET CRAIOVA HIGH POWER DIVISION

HIGH POWER LABORATORY

"Ovidiu Rarinca"

200746-CRAIOVA, Blvd. DECEBAL No. 118A, ROMANIA
Matriculation certificate: J16/312/1999, VAT number RO387 1599
Phone: +40 (351) 402 427; Fax: +40 (251) 415482; (351) 404 890;
E-mail: imp@icmet.ro

acreditat pentru
ÎNCERCARE



SR EN ISO/CEI 17025:2005
CERTIFICAT DE ACREDITARE
nr. LI 004/2010

TEST REPORT No. 11160

CUSTOMER: ESER PREFABRIK A.Ş
Organize Sanayi Bölgesi 1, Kisim 6. Cadde No. 42 Sivas / TURKEY

MANUFACTURER: ESER PREFABRIK A.Ş
Organize Sanayi Bölgesi 1, Kisim 6. Cadde No. 42 Sivas / TURKEY

TESTED PRODUCT: 1000 kVA, 36 / 0.4 kV Prefabricated Monobloc Transformer Substation

REFERENCE STANDARD: IEC 62271-202/2006, clause 6.4

TEST PERFORMED: Short-time and peak withstand current tests on earthing circuit

TEST DATE: 27.06.2011

TEST RESULT: Passed the test

Report has 14 pages and it is edited in 4 copies from which copy 1 for laboratory and copies 2, 3 and 4 for customer.

HEAD OF HIGH POWER DIVISION:

Dr. Eng. George Curcanu

HEAD OF LABORATORY:

Eng. Constantin Iancu



DATE OF ISSUE: 22.07.2011

1. Results refer to test product only.
2. Publication or reproduction of the contents of this report in any other form unless its complete photocopying is not allowed without writing approval of division to which laboratory belongs to.
3. Accreditation of the laboratory or any of its Test Reports issued under accreditation regime do not constitute or do not imply themselves an approval of the product by the accreditation body.